



Address (Head Office)
7 Redland Drive
MITCHAM VIC 3132

Office Locations
VIC NSW WA QLD

Postal Address
52 Cooper Road
COCKBURN CENTRAL WA 6164

Freecall: 1300 364 005
www.ektimo.com.au
ABN: 86 600 381 413

Report Number R007225
Emission Testing Report
Supagas, Ingleburn



Document Information

Client Name: Supagas
 Report Number: R007225
 Date of Issue: 18 February 2019
 Attention: Reza Pourdarvish
 Address: 5 Benson Road
 Ingleburn NSW 2565
 Testing Laboratory: Ektimo Pty Ltd, ABN 86 600 381 413

Report Status

Format	Document Number	Report Date	Prepared By	Reviewed By (1)	Reviewed By (2)
Preliminary Report	-	-	-	-	-
Draft Report	-	-	-	-	-
Final Report	R007225	18/02/2019	JWe	SCo	ADa
Amend Report	-	-	-	-	-

Template Version: 171218

Amendment Record

Document Number	Initiator	Report Date	Section	Reason
Nil	-	-	-	-

Report Authorisation



Steven Cooper
Client Manager

NATA Accredited Laboratory
No. 14601

Accredited for compliance with ISO/IEC 17025 - Testing. NATA is a signatory to the ILAC mutual recognition arrangement for the mutual recognition of the equivalence of testing, calibration and inspection reports.

Table of Contents

1	Executive Summary	4
2	Licence Comparison	4
3	Results	5
3.1	EPA 1 – CO ₂ Production Plant Absorber Tower Stack	5
4	Plant Operating Conditions	6
5	Test Methods.....	6
6	Quality Assurance/Quality Control Information	6
7	Definitions	7

1 EXECUTIVE SUMMARY

Ektimo was engaged by Supagas to perform annual emission testing pursuant to their Environment Protection Licence 20022.

Monitoring was performed as follows:

Location	Test Date	Test Parameters*
EPA 1 - CO ₂ Production Plant Absorber Tower Stack	15 February 2019	Nitrogen oxides, carbon monoxide, carbon dioxide, oxygen

* Flow rate, velocity, temperature and moisture were also determined.

All results are reported on a dry basis at STP.

Plant operating conditions have been noted in the report.

2 LICENCE COMPARISON

The following licence comparison table shows that all analytes highlighted in green are below the licence limit set by the NSW EPA as per licence 20022 (last amended on 10/07/14).

EPA No.	Location Description	Pollutant	Units	Licence limit	Detected values 15/02/2019	Detected values (corrected to 3% O ₂)
1	CO ₂ Production Plant Absorber Tower Stack	Nitrogen Oxides	mg/m ³	230	120	120

3 RESULTS

3.1 EPA 1 – CO₂ Production Plant Absorber Tower Stack

Date	15/02/2019	Client	Supagas
Report	R007225	Stack ID	CO2 Production Plant Absorber Tower Stack
Licence No.	20022	Location	Ingleburn
Ektimo Staff	Steven Cooper	State	NSW
Process Conditions	Please refer to client records.		

190207

Sampling Plane Details	
Sampling plane dimensions	1140 mm
Sampling plane area	1.02 m ²
Access & height of ports	Elevated work platform 10 m
Duct orientation & shape	Vertical Circular
Downstream disturbance	Exit 0.3 D
Upstream disturbance	Junction 0 D
No. traverses & points sampled	2 20
Sample plane compliance to AS4323.1	Non-compliant

Comments	
Sampling was conducted via a 1/2 inch stainless steel duct secured permanently at the sampling plane. Flow Rate, velocity, temperature and moisture measurements were taken from the exit of this discharge point as no removable ports at the sampling plane are evident.	
The sampling plane is deemed to be non-compliant due to the following reasons:	
The gas velocity at some or all sampling points is less than 3 m/s	
The downstream disturbance is <1D from the sampling plane	
The upstream disturbance is <2D from the sampling plane	

Stack Parameters			
Moisture content, %v/v	11 (saturated)		
Gas molecular weight, g/g mole	27.3 (wet)	28.4 (dry)	
Gas density at STP, kg/m ³	1.22 (wet)	1.27 (dry)	
% Oxygen correction & Factor	3 %	0.93	
Gas Flow Parameters			
Flow measurement time(s) (hhmm)	0905 & 1016		
Temperature, °C	49		
Temperature, K	322		
Velocity at sampling plane, m/s	2		
Volumetric flow rate, actual, m ³ /s	2.1		
Volumetric flow rate (wet STP), m ³ /s	1.8		
Volumetric flow rate (dry STP), m ³ /s	1.6		
Mass flow rate (wet basis), kg/hour	7800		
Velocity difference, %	-1		

Gas Analyser Results	Sampling time	Average			Minimum			Maximum		
		0914 - 1013			0914 - 1013			0914 - 1013		
		Corrected to 3%			Corrected to 3%			Corrected to 3%		
Combustion Gases	Concentration mg/m ³	O ₂ mg/m ³	Mass Rate g/min	Concentration mg/m ³	O ₂ mg/m ³	Mass Rate g/min	Concentration mg/m ³	O ₂ mg/m ³	Mass Rate g/min	
Nitrogen oxides (as NO ₂)		120	120	12	120	110	11	130	120	12
Carbon monoxide		52	48	4.9	32	30	3.1	95	89	9
Carbon dioxide		Concentration %			Concentration %			Concentration %		
		1.3			1.2			1.5		
Oxygen		1.7			1.4			2		

4 PLANT OPERATING CONDITIONS

Unless otherwise stated, the plant operating conditions were normal at the time of testing. See Supagas's records for complete process conditions.

5 TEST METHODS

All sampling and analysis was performed by Ektimo unless otherwise specified. Specific details of the methods are available upon request.

Parameter	Sampling Method	Analysis Method	Uncertainty*	NATA Accredited	
				Sampling	Analysis
Sample plane criteria	NSW TM-1	NA	-	✓	NA
Flow rate, temperature and velocity	NSW TM-2	NA	8%, 2%, 7%	✓	NA
Moisture content	NSW TM-22	NSW TM-22	19%	✓	✓
Molecular weight	NSW TM-23	USEPA 3A	not specified	✓	✓
Carbon dioxide	NSW TM-24	NSW TM-24	13%	✓	✓
Carbon monoxide	NSW TM-32	NSW TM-32	12%	✓	✓
Nitrogen oxides (NO _x)	NSW TM-11	NSW TM-11	12%	✓	✓
Oxygen	NSW TM-25	NSW TM-25	13%	✓	✓

181219

* Uncertainty values cited in this table are calculated at the 95% confidence level (coverage factor = 2)

6 QUALITY ASSURANCE/QUALITY CONTROL INFORMATION

Ektimo is accredited by the National Association of Testing Authorities (NATA) for the sampling and analysis of air pollutants from industrial sources. Unless otherwise stated test methods used are accredited with the National Association of Testing Authorities. For full details, search for Ektimo at NATA's website www.nata.com.au.

Ektimo is accredited by NATA (National Association of Testing Authorities) to ISO/IEC 17025 - Testing. ISO/IEC 17025 - Testing requires that a laboratory have adequate equipment to perform the testing, as well as laboratory personnel with the competence to perform the testing. This quality assurance system is administered and maintained by the Quality Director.

NATA is a member of APLAC (Asia Pacific Laboratory Accreditation Co-operation) and of ILAC (International Laboratory Accreditation Co-operation). Through the mutual recognition arrangements with both of these organisations, NATA accreditation is recognised worldwide.

7 DEFINITIONS

The following symbols and abbreviations may be used in this test report:

% v/v	Volume to volume ratio, dry or wet basis
~	Approximately
<	Less than
>	Greater than
≥	Greater than or equal to
APHA	American public health association, Standard Methods for the Examination of Water and Waste Water
AS	Australian Standard
BSP	British standard pipe
CARB	Californian Air Resources Board
CEM	Continuous Emission Monitoring
CEMS	Continuous Emission Monitoring System
CTM	Conditional test method
D	Duct diameter or equivalent duct diameter for rectangular ducts
D ₅₀	'Cut size' of a cyclone defined as the particle diameter at which the cyclone achieves a 50% collection efficiency ie. half of the particles are retained by the cyclone and half are not and pass through it to the next stage. The D ₅₀ method simplifies the capture efficiency distribution by assuming that a given cyclone stage captures all of the particles with a diameter equal to or greater than the D ₅₀ of that cyclone and less than the D ₅₀ of the preceding cyclone.
DECC	Department of Environment & Climate Change (NSW)
Disturbance	A flow obstruction or instability in the direction of the flow which may impede accurate flow determination. This includes centrifugal fans, axial fans, partially closed or closed dampers, louvres, bends, connections, junctions, direction changes or changes in pipe diameter.
DWER	Department of Water and Environmental Regulation (WA)
DEHP	Department of Environment and Heritage Protection (QLD)
EPA	Environment Protection Authority
FTIR	Fourier Transform Infra-red
ISC	Intersociety committee, Methods of Air Sampling and Analysis
ISO	International Organisation for Standardisation
Lower Bound	Defines values reported below detection as equal to zero.
Medium Bound	Defines values reported below detection are equal to half the detection limit.
NA	Not applicable
NATA	National Association of Testing Authorities
NIOSH	National Institute of Occupational Safety and Health
NT	Not tested or results not required
OM	Other approved method
OU	The number of odour units per unit of volume. The numerical value of the odour concentration is equal to the number of dilutions to arrive at the odour threshold (50% panel response).
PM ₁₀	Atmospheric suspended particulate matter having an equivalent aerodynamic diameter of less than approximately 10 microns (µm).
PM _{2.5}	Atmospheric suspended particulate matter having an equivalent aerodynamic diameter of less than approximately 2.5 microns (µm).
PSA	Particle size analysis
RATA	Relative Accuracy Test Audit
Semi-quantified VOCs	Unknown VOCs (those not matching a standard compound), are identified by matching the mass spectrum of the chromatographic peak to the NIST Standard Reference Database (version 14.0), with a match quality exceeding 70%. An estimated concentration will be determined by matching the integrated area of the peak with the nearest suitable compound in the analytical calibration standard mixture.
STP	Standard temperature and pressure. Gas volumes and concentrations are expressed on a dry basis at 0°C, at discharge oxygen concentration and an absolute pressure of 101.325 kPa, unless otherwise specified.
TM	Test Method
TOC	The sum of all compounds of carbon which contain at least one carbon to carbon bond, plus methane and its derivatives.
USEPA	United States Environmental Protection Agency
VDI	Verein Deutscher Ingenieure (Association of German Engineers)
Vic EPA	Victorian Environment Protection Authority
VOC	Any chemical compound based on carbon with a vapour pressure of at least 0.010 kPa at 25°C or having a corresponding volatility under the particular conditions of use. These compounds may contain oxygen, nitrogen and other elements, but specifically excluded are carbon monoxide, carbon dioxide, carbonic acid, metallic carbides and carbonate salts.
XRD	X-ray Diffractometry
Upper Bound	Defines values reported below detection are equal to the detection limit.